Fyrehalt EVOLUTION

Integrity only concertina type fire curtain specification

PERFORMANCE REQUIREMENT:

The concertina type fire curtains shall be supplied and installed in accordance with AS1905.2:2014 except that the primary means of activation is to be from an AS1670.1:2018 smoke detection system. When fire tested in accordance with Clause 3 Determination of Fire Resistance they shall provide a minimum Fire Resistance Level (FRL) of -/120/- and radiation transmission of no more than 10kW/m2 measured at 365mm at 30 minutes. The fabric barrier shall have fire hazard properties of a Group 1 rating when tested in accordance with NCC Specification C1.10 Clause 4 Wall and Ceiling Linings.

The fire curtains shall resist a pressure differential of no more than 40 Pa when fully deployed. High pressure resistance available on request.

PRODUCT SPECIFIED

Fyrehalt – EVOLUTION concertina fire curtain by Smoke Control T: 1300 665 471; info@smokecontrol.com.au or approved equivalent.

a) -/120/- FRL AS1530.4:2014
b) Smoke leakage: ≤ 75m3/hour AS1530.7:1998 (3.3 x 3.3m tested system).
c) Maximum size;
    i) 20m long x 4m height per "leg" of curtain.
d) Deployment speed nominally 150mm/s
e) Dimensions
    i) Headbox –
        i. Drop height up to 3m; 130mm H x 490mm W
        ii. Drop height up to 4m; 260mm H x 490mm W
    ii) Side Guide (if required for non-enclosed shape) – refer to product drawings for side guide size and surrounding wall integration
f) Power requirements – 240v 10amp GPO and peak current draw 3.5amps per motor. Nominally 1 motor per 6m of curtain run.
g) Alarm input – 0V nominally closed contactsa
h) Pressure resistance maximum;
    i) 0Pa when deploying
    ii) 40Pa when deployed. For higher pressures please contact Smoke Control Technical Department.
i) System weight;
    i) 40kg/m of system length up to 3m H
    ii) 45kg/m of system length up to 4m H
j) Supporting construction type;
    i) Masonry
    ii) Concrete
    iii) Fire rated plasterboard with steel or timber stud.
k) Approved installation configuration;
    i) Headbox;
        i. Fixed under the slab or into fire rated bulkhead
    ii) Side guides;
        i. Face fixed to the wall

Ancillary items required; (delete not applicable)

l) Control system: Shall allow fail safe operation on receipt of a general building alarm signal and automatic rewind on reset of the alarm from the Fire Indicator Panel (FIP) without the assistance of a technician. The Control system shall also provide an *anti-tilt* system to prevent uneven rewinding of the product and subsequent self-destruction.

m) Staged Deployment: Staged deployment shall allow the fire curtain to deploy to 2m above the finished floor level, pause for 30 seconds and then deploy to the floor.
n) Battery back up; Shall be installed to reduce the likelihood of nuisance deployments. Standard battery time is 4hours, extended periods available on request.
o) Rewind switches (operating ΔPa = 0): shall be installed on *(delete not applicable)* both sides/one side of the nominated smoke containment screens. They shall allow the system to rewind no more than 2.1m and redeploy within 20 seconds.
p) Exclusion Zone Sensors; IRS36 shall be installed in accordance with Smoke Control's recommendations to protect each fire curtain asset during normal building use and significantly increase the likelihood of full deployment when in fire mode.
q) Sounders and strobes: Shall be installed on *(delete not applicable)* both sides/on the same side as the egress path and operate on a signal from the FIP.
r) Fire Rated Bulkhead; shall be installed to provide an FRL of -/120/120 when fire tested in accordance with AS1530.4 and shall facilitate any service penetrations to be installed and certified in accordance with AS4072.1
s) Maintenance: All fire curtains shall be listed on the Essential Services Register and shall be maintained by competent technicians in accordance with AS1851 and the manufacturers recommendations
t) Third Party Product Listing: The product shall be manufactured under the Third Party Product Listing scheme known as the Warnock Hersey Mark and shall bear the Warnock Hersey Certification Mark.

APPLICATIONS

- Atrium separation in leu of bounding walls in accordance with clauses NCC G3.3 and G3.4.
- Non-required stairways, ramps, and escalators (NCC D1.12 & NCC Spec D1.12)
- Protection of openings in fire compartment walls (NCC C3.5)
- Separation of fire compartment where it exceed maximum size or volume (NCC C2)

Note: Some applications listed above may require a Performance Solution to be compliant. Please check with your Certifier prior to specifying this product.

INSTALLATION

Fire Curtains

The fire curtains shall be installed, certified, commissioned and tagged in accordance with AS1905.2 -2005 and this Fire Engineering Report by an ISO9001 Quality, ISO18001 WHS and ISO14001 Environment Accredited manufacturer.

When installed the system shall consist of a single overhead barrel for the full width of the opening. While some Registered Testing Authorities provide Formal Opinions in regards to the expected fire resistance level of fire curtains, they do not discuss nor provide a warranty in regards to their reliability. Experience shows that some manufacturer designs of fire curtains do not operate reliably once installed and attract extraordinarily high maintenance costs. For this reason, multiple barrel, overlapped fire curtains are deemed not equivalent to this specification on this project and shall not be substituted for a single barrel continuous drive system.

Threshold

Unless addressed as part of an appropriate performance solution the curtain must deploy onto a fire rated or non-combustible threshold as per requirements of AS1905.2:2005 and AS1530.4:2014. Maximum gap permitted at threshold 25mm.

Fire Rated Bulkheads

Installation of the fire curtains suspended below the concrete slab shall only be permitted if the system has been fire tested in this configuration and approved by a Registered Testing Authority for the sizes required in this project. That is; the suspension system fully exposed to fire from both directions without protection of a fire rated wall/bulkhead. If the system has not been fire tested in this configuration, a fire rated bulkhead shall be installed to support the fire curtain system. For clarity, the fixing of the fire curtain head box shall be directly to the fire rated bulkhead as per the fire tested prototype.

The fire rated bulkhead shall be installed as a 3-sided bulkhead (the forth side is provided by the concrete slab) to provide a minimum of -/120/120 fire resistance level when tested in accordance with AS1530.4 and provide

complete encasement of the fire curtain suspension system. This configuration will allow for certification of any service penetrations which will also be required to be certified in accordance with AS4072.1.

COMMISSIONING

Once installed it shall be demonstrated that the system shall fail safe close on loss of power using mains power in combination with battery backup and on the receipt of an alarm signal. On reset of power and the alarm signal the system shall automatically rewind to its standby position without the assistance of an occupant or technician.

The fire curtains shall also be commissioned in conjunction with the building's smoke management system. The smoke management system shall be balanced to operate without adverse effects to the fire curtain. The fire curtains must be tested a minimum of 3 consecutive times on general building alarm without failure.

The building's smoke management system shall not impede the operation of the fire curtain. A time delay of 60 seconds shall be incorporated into the smoke management system before it operates to allow the fire curtain to deploy to its fire mode position without interference. This shall be programmed within the Fire Indicator Panel. Consideration shall be made for the staged deployment of the fire curtain.

Similarly, a time delay of 60 seconds shall be incorporated into the reset of the alarm signal to fire curtain to ensure the smoke management system has ceased operation and the effects of pressure differentials have been dispersed prior to rewind of the curtain.

Certificates of Compliance shall be issued by the sub-contractor in accordance with National Construction Code A2.2 and A2.3 Evidence of Suitability and AS1905.2 Clause 7 Certification.

All details and approvals are current as of the date displayed. This document supersedes all previous versions.