



Smokehalt V

Single coil small span smoke curtain specification

PERFORMANCE REQUIREMENT:

The vertical smoke curtains shall comply with the NCC Specification E2.2b requirements for smoke baffles/curtains. The vertical smoke curtains shall be supplied and installed in accordance with EN12101-1 except that the primary means of activation is to be from an AS1670.1:2018 smoke detection system with up to a DH120. The fabric barrier shall have fire hazard properties of a Group 1 rating when tested in accordance with NCC Specification C1.10 Clause 4 Wall and Ceiling linings.

The system shall deploy to **(delete not applicable)** floor level/2.1m above floor level/other Xm above floor level.

The smoke baffles/curtains shall resist a pressure differential of no more than 25 Pa when fully deployed and not deflect more than 15 degrees from the vertical. When installed, **(delete not applicable)** the system shall incorporate side guides/shall not incorporate side guides and gaps along the vertical sides shall not exceed 30mm.

PRODUCT SPECIFIED

Smokehalt V smoke curtain by Smoke Control T: 1300 665 471; info@smokecontrol.com.au or approved equivalent.

System parameters;

- a) Smoke Leakage: 0.115 m³/min/m² AS1530.7:1998 (3.3 x 3.3m tested system).
- b) Rating: D30, D60, D120 (without guides), DH30, DH60, DH120 (with guides)
- c) Maximum size;
 - i) 8m W x 3m H
 - ii) 6m W x 4m H
- d) Deployment speed nominally 150mm/s
- e) Dimensions
 - i) Headbox – 165mm H x 165mm D
 - ii) Side Guide – 100mm W x 50mm D
- f) Power requirements – 240v 10amp GPO, peak current draw 2.1amps
- g) Alarm Input – 0V nominally closed contacts
- h) Pressure resistance maximum;
 - i) 0Pa when deploying
 - ii) 20Pa when deployed
- i) System weight;
 - i) 20kg/m of system width up to 3m H
 - ii) 25kg/m of system width up to 4m H
- j) Supporting construction type;
 - i) Masonry
 - ii) Concrete
 - iii) Fire rated plasterboard with steel or timber stud.
- k) Approved installation configuration;
 - i) Headbox;
 - i. Face fixed to the wall
 - ii. Fixed under the slab/into the wall
 - ii) Side guides;
 - i. Face fixed to the wall
 - ii. Fixed in the opening

Ancillary items required; **(delete not applicable)**

- i) Control system: Shall allow fail safe operation on receipt of a general building alarm signal and automatic rewind on reset of the alarm from the Fire Indicator Panel (FIP) without the assistance of a technician.
 - ii) Staged Deployment: Staged deployment shall allow the fire curtain to deploy to 2m above the finished floor level, pause for 30 seconds and then deploy to the floor. (other configurations available on request)
 - iii) Battery back up; Shall be installed to reduce the likelihood of nuisance deployments and allow 5 complete open-close cycles.
 - iv) Rewind switches (operating $\Delta Pa = 0$): shall be installed on *(delete not applicable)* both sides/one side of the nominated smoke containment screens. They shall allow the system to rewind no more than 2.1m and redeploy within 20 seconds from top position.
 - v) Exclusion Zone Sensors; IRS36 shall be installed in accordance with Smoke Control's recommendations to protect each fire curtain asset during normal building use and significantly increase the likelihood of full deployment when in fire mode.
 - vi) Sounders and strobes: Shall be installed on *(delete not applicable)* both sides/on the same side as the egress path and operate on a signal from the FIP. Sounders and strobes: Shall be installed on *(delete not applicable)* both sides/on the same side as the egress path and operate on a signal from the FIP.
 - vii) Smoke baffles above the head box; shall be installed to provide an effective smoke seal to any gaps between the head box and the slab, and should be of non-combustible construction. Where services penetrate this baffle they shall be treated to ensure that there are no gaps between the service penetration and baffle.
 - viii) Corner posts: When side guides are required, corner posts shall be installed at smoke curtain junctions and shall also provide a seal against smoke movement.
 - ix) Third Party Product Listing: The product shall be manufactured under the Third Party Product Listing scheme known as the Warnock Hersey Mark and shall bear the Warnock Hersey Certification Mark.
- Maintenance: All smoke curtains shall be listed on the Essential Services Register and shall be maintained by competent technicians in accordance with AS1851 and the manufacturers recommendations

APPLICATIONS

- Atrium separation in lieu of bounding walls in accordance with clauses NCC G3.3 and G3.4.
- Automatic smoke baffles forming smoke reservoirs for mechanical smoke exhaust systems (NCC Specification E2.2b)
- Removal of smoke lobbies for lifts (NCC D1.7, D2.6)
- Openings in smoke proof walls health-care and residential care buildings (NCC Spec C2.5)

Note: Some applications listed above may require a Performance Solution to be compliant. Please check with your Certifier prior to specifying this product.

INSTALLATION

Smoke Curtains

The fire curtains shall be installed, certified, commissioned and tagged in accordance with AS1905.2 -2005 and this Fire Engineering Report by an ISO9001 Quality, ISO18001 WHS and ISO14001 Environment Accredited manufacturer.

When installed the system shall consist of a single overhead barrel for the full width of the opening. Experience shows that some manufacturer designs of smoke curtains do not operate reliably once installed and attract extraordinarily high maintenance costs. For this reason multiple barrel, overlapped smoke curtains are deemed not equivalent to this specification on this project and shall not be substituted for a single barrel continuous span system.

Gaps at Perimeter of Curtains System where leakage is permitted in performance solution (no side guides)

Smoke Curtains may be installed without side guides in accordance with gaps and spacing as indicated in EN12101-1, Section 5.5 – Smoke Leakage (containment efficiency).

Threshold

Unless addressed as part of an appropriate performance solution the curtain must deploy onto a fire rated or non-combustible threshold as per requirements of AS1905.2:2005 and AS1530.4:2014. Maximum gap permitted at threshold 25mm

Smoke Resistant Bulkheads

The smoke resistant bulkhead shall be installed using smoke wall construction as defined by the NCC or by utilising the same fabric material utilised in the smoke curtains. Any service penetrations shall be treated so that there are no gaps between the services and the baffle.

COMMISSIONING

Once installed it shall be demonstrated that the system shall fail safe close on loss of power using mains power in combination with battery backup and on the receipt of an alarm signal. On reset of power and the alarm signal the system shall automatically rewind to its standby position without the assistance of an occupant or technician.

The smoke curtains shall also be commissioned in conjunction with the building's smoke management system. The smoke management system shall be balanced to operate without adverse effects to the smoke curtain. The smoke curtains must be tested a minimum of 3 consecutive times on general building alarm without failure.

The building's smoke management system shall not impede the operation of the smoke curtain. A time delay of 60 seconds shall be incorporated into the smoke management system before it operates to allow the smoke curtain to deploy to its fire mode position without interference. This shall be programmed within the Fire Indicator Panel. Consideration shall be made for the staged deployment of the smoke curtain.

Similarly, a time delay of 60 seconds shall be incorporated into the reset of the alarm signal to smoke curtain to ensure the smoke management system has ceased operation and the effects of pressure differentials have been dispersed prior to rewind of the curtain.

Certificates of Compliance shall be issued by the sub-contractor in accordance with National Construction Code Clause A2.2 and A2.3 Evidence of Suitability and AS1905.2 Clause 7 Certification.

All details and approvals are current as of the date displayed. This document supersedes all previous versions.